



April 25, 2025

Josh Rosen
VHB
1 Cedar Street
Providence, RI 02903

**Re: Water Availability – Coventry Centre, New London Turnpike and Arnold Road,
Coventry, RI**

Dear Mr. Rosen,

In reference to your request dated April 24, 2025, there is an existing water main along Arnold Road and New London Turnpike adjacent to the above-mentioned property. Water service can be provided, contingent upon the proposed service being able to meet the demands of the project.

A complete design application, as outlined in Part III of the KCWA Rules and Regulations, is required. This application must include the water demand requirements and plans for the proposed redevelopment of the buildings. A computerized hydraulic model is required. Ref. section 3.8 of the Kent County Water Authority rules and regulations.

Please contact Nicole Campagnone at our office to review the information needed for the modeling process.

A copy of the KCWA Rules and Regulations is available online at www.kentcountywater.org.

Feel free to contact us should you have any questions regarding this matter.

Very truly yours,
Kent County Water Authority

A handwritten signature in black ink, appearing to read "Gary Glenn", is written over the printed name.

Gary Glenn
Senior Manager of Construction